

Statement of conformity


Abbeville, 5th of September 2024

We hereby declare that Biofloor 9100 manifold we manufactured, after completing testing and qualification in France in our test bench, has met the following conditions:

- Maximal static pressure 40 bars (room temperature).
- 6 bars at 65 °C for 2,500 hours.
- 10 bars at 93°C for 1,000 hours.

It fully complies with all specified requirements and applicable standards.

Quality manager



Matthieu DESCHAMPS
Responsable Bureau D'Etudes
le 20/09/2024

Aalberts hydronic flow control

Aalberts hfc Comap SA au capital social de 37 696 905 €

77-79 Boulevard de la Bataille de Stalingrad / Parkview bâtiment A / 69100 Villeurbanne

IBAN FR76 3005 6005 0600 1671 139 / BIC CCFRFRPP / Numéro TVA FR46302304068

+33 (0) 986 000 401 / fr.info@aalberts-hfc.com / aalberts-hfc.com / comap.aalberts-hfc.com/fr

Deklaracja zgodności


Abbeville, 5 września 2024 r.

Niniejszym oświadczamy, że rozdzielacz Biofloor 9100, wyprodukowany przez nas, po zakończeniu testów i kwalifikacji we Francji na naszym stanowisku testowym, spełnił wymagania dotyczące przepływu:

- Maksymalne ciśnienie statyczne: 40 bar (temperatura pokojowa)
- 6 bar w temperaturze 65°C przez 2500 godzin
- 10 bar w temperaturze 93°C przez 1000 godzin

Produkt w pełni spełnia wszystkie wymagania specyfikacji oraz obowiązujące normy.

Kierownik ds. Jakości



Mathieu DESCHAMPS
Responsable Bureau D'Etude
le 20/09/2024

Aalberts hydronic flow control

Aalberts hfc Comap SA au capital social de 37 696 905 €

77-79 Boulevard de la Bataille de Stalingrad / Parkview bâtiment A / 69100 Villeurbanne

IBAN FR76 3005 6005 0800 1671 139 / BIC CCFRFRPP / Numéro TVA FR46302304068

+33 (0) 986 000 401 / fr.info@aalberts-hfc.com / aalberts-hfc.com / comap.aalberts-hfc.com/fr